



① - 277V INSTA-HOT INSTALLED UNDER SINK.
REQUIRES 277V 30 AMP CIRCUIT AND EQUIPMENT DISCONNECTING MEANS.

DESIGN/BUILD NOTES:

1. THESE DRAWINGS AND SPECIFICATIONS ARE THE SOLE PROPERTY OF AND COPYRIGHT BY PROFESSIONAL ELECTRICAL SERVICES, INC. THESE PLANS SHALL NOT BE USED, IN WHOLE OR IN PART BY ANY ENTITY OTHER THAN PROFESSIONAL ELECTRICAL SERVICES, INC. THESE PLANS REPRESENT A SCHEMATIC DESIGN/BUILD LAYOUT OF THE ELECTRICAL SYSTEMS; THESE PLANS MAY NOT INDICATE ALL MATERIALS THAT WILL BE REQUIRED TO PROVIDE A COMPLETE AND OPERATING ELECTRICAL SYSTEMS.
2. THESE PLANS WERE PREPARED UNDER THE EXEMPTION TO DIVISION 3 OF THE CALIFORNIA BUSINESS AND PROFESSIONS CODE BY SECTION 5537.2, AS THE LICENSED CONTRACTOR RESPONSIBLE FOR THE PREPARATION OF THESE DRAWINGS, ONLY PROFESSIONAL ELECTRICAL SERVICES, INC. MAY UTILIZE THEM.

PROFESSIONAL ELECTRICAL SERVICES

OFFICE TENANT IMPROVEMENT VALENCIA, CA

REVISIONS:
A PLAN CHECK CORRECTION
15 JUNE 2012

DRAWING TITLE:

POWER DRAWING

DRAWN BY:
D. URSINI

SCALE:
0' - 1/4" = 1' - 0"

DRAWN DATE:

15 MAY 2012

SHEET NO.

E-3

2028 VERDUGO BLVD. #1034
MONTROSE, CA 91020
TEL: (818) 834-8512